



Indorama Ventures Fibers Germany GmbH

Trademark Service

Max-Fischer-Str. 11

86399 Bobingen, Germany

trademarkservice.IVFG@de.indorama.net

Tel. +49 8234 9688 1673

[www.indoramaventures.com](http://www.indoramaventures.com)



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
Bangatan 8  
51182 Kinna  
Sweden

**Application No.:** 250357

**Date of issue:** 10.07.2025

**Valid until:** 10.07.2030

**Article name:** Sand

**Color:** Blue

**End use:** Curtains

**Square weight (g/m<sup>2</sup>):** 300

According to customer specification

**Composition of the raw materials:** 100% Polyester

**Composition of the fabric:** 100% Trevira CS

**Yarn:** Warp, 10 / 2 Nm Trevira® Type T270,

Yarn supplier Vlnap

Weft, 10 / 2 Nm Trevira® Type T270,

Yarn supplier Vlnap

The tested article Sand with application no. 250357 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

**INDORAMA**  
VENTURES

Indispensable Chemistry





This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

This article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)

250357

