



Indorama Ventures Fibers Germany GmbH

Trademark Service

Max-Fischer-Str. 11

86399 Bobingen, Germany

trademarkservice.IVFG@de.indorama.net

Tel. +49 8234 9688 1673

www.indoramaventures.com



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
Bangatan 8  
51182 Kinna  
Sweden

<b>Application No.:</b>	<b>260023</b>
<b>Date of issue:</b>	18.02.2026
<b>Valid until:</b>	18.02.2031
<b>Article name:</b>	Rey
<b>Color:</b>	Beige
<b>End use:</b>	Curtains
<b>Square weight (g/m<sup>2</sup>):</b>	220
According to customer specification	
<b>Composition of the raw materials:</b>	100% Polyester
<b>Composition of the fabric:</b>	100% Trevira CS
<b>Yarn:</b>	Warp, 60 / 2 Nm Trevira® Type T270, Yarn supplier Lampertsmuhle Weft, 60 / 2 Nm Trevira® Type T270, Yarn supplier Lampertsmuhle Weft, 85 / 2 Nm Trevira® Type T270, Yarn supplier Fil Man Made

The tested article Rey with application no. 260023 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

**INDORAMA**  
VENTURES

Indispensable Chemistry

The article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 10 January 2024.

The article can also meet the requirements for the fire index BKZ 5.3 (BKZ = fire index, combustibility 5 = flame retardant, level of smoke emission 3 = low smoke emission) according to the Swiss standard SN 198898.

The article meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

The article meets also the requirements according to British Standard BS 5867 part 2 type C.

The article meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)

