



## Approval of the Trademark Trevira CS®

AB Ludvig Svensson  
Bangatan 8  
51182 Kinna  
Sweden

|                                          |                 |
|------------------------------------------|-----------------|
| <b>Application No.:</b>                  | 210219          |
| <b>Date of issue:</b>                    | 01.04.2021      |
| <b>Valid until:</b>                      | 01.04.2026      |
| <b>Article name:</b>                     | Tune            |
| <b>End use:</b>                          | Curtains        |
| <b>Square weight (g/m<sup>2</sup>):</b>  | 360             |
| According to customer specification      |                 |
| <b>Composition of the raw materials:</b> | Polyester 100%  |
| <b>Composition of the fabric:</b>        | Trevira CS 100% |

**Yarn:** Warp, 167 f 64 x 1 dtex Trevira® Type 594E,  
Yarn supplier Trevira  
Weft, 40 / 2 Nm Trevira® Type 270,  
Yarn supplier Selvafil  
Weft, 20 / 2 Nm Trevira® Type 270,  
Yarn supplier Lampertsmuhle

The tested article Tune with application no. 210219 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH  
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany  
E-Mail: [trademark.service@trevira.com](mailto:trademark.service@trevira.com)